

FMEC Water Heater Control Wiring Specification

- Water heater controls must be installed on the outside of dwelling
- Use PVC or bakelite box without threaded hubs only
- Adequate side clearances, top clearance and height from ground must be followed
- Electrical inspection required. In Freeborn County, contact Todd Drescher, 507-473-0092. Mower County, except cities of Austin, Lyle, Mapleview and Townships of Austin, Lansing & Lyle, contact Steve Roberts, 507-254-4272. Cities of Austin, Lyle, Lansing and Townships of Austin, Lansing & Lyle, contact Aaron Goslee, 507-440-1433.

